Roberts, L. G. W., Champneys, A. R., Di Bernardo, M., & Bell, K. (2015). Analytical Approximations of Critical Clearing Time for Parametric Analysis of Power System Transient Stability. *IEEE Journal of Emerging and Selected Topics in Circuits and Systems*, 5(3), 465-476. <https://doi.org/10.1109/JETCAS.2015.2467111>

Peer reviewed version

Link to published version (if available):
[10.1109/JETCAS.2015.2467111](https://doi.org/10.1109/JETCAS.2015.2467111)

[Link to publication record in Explore Bristol Research](#)
PDF-document

© 2015 IEEE. Personal use of this material is permitted. Permission from IEEE must be obtained for all other uses, in any current or future media, including reprinting/republishing this material for advertising or promotional purposes, creating new collective works, for resale or redistribution to servers or lists, or reuse of any copyrighted component of this work in other works.

University of Bristol - Explore Bristol Research

General rights

This document is made available in accordance with publisher policies. Please cite only the published version using the reference above. Full terms of use are available:
<http://www.bristol.ac.uk/red/research-policy/pure/user-guides/ebr-terms/>

Analytical approximations of critical clearing time for parametric analysis of power system transient stability

Lewis G. W. Roberts, *Student Member, IEEE*, Alan R. Champneys, Keith R. W. Bell, *Member, IEEE*, Mario di Bernardo, *Fellow, IEEE*.

Abstract—An analytic approximation for the critical clearing time (CCT) metric is derived from direct methods for power system stability. The formula has been designed to incorporate as many features of transient stability analysis as possible such as different fault locations and different post-fault network states. The purpose of this metric is to analyse trends in stability (in terms of CCT) of power systems under the variation of a system parameter. The performance of this metric to measure stability trends is demonstrated on an aggregated power network, the so-called two machine infinite bus network, by varying load parameters in the full bus admittance matrix using numerical continuation. The metric is compared to two other expressions for the CCT which incorporate additional non-linearities present in the model.

Index Terms—power system stability, stability metrics, swing equation, numerical continuation, critical clearing time

I. INTRODUCTION

THE COMPLEX dynamics of electric power systems have long been the subject of intense research particularly in the area of stability. Effective stability metrics provide control inputs and assist the system operator to ensure that a power system maintains synchrony after the network suffers a fault, i.e. that it exhibits transient stability. A traditional transient stability metric for short circuit faults on a power network is the so-called *critical clearing time* (CCT) [1], [2]. The CCT provides an upper bound on the duration of a short circuit on a power network before it is removed - ‘cleared’ - by the action of protection mechanisms to isolate the faulted circuit such that the system will regain synchronisation once the fault is cleared. In general, the CCT is a useful metric for power system design; by allowing the severity of different situations and the effectiveness of different interventions (generation re-dispatches, control modifications or network reinforcements) to be compared.

Currently, there are practical developments in power systems that promise to radically change power system dynamic behaviour. For example, the gradual substitution of power generated from large, synchronous machines by asynchronous machines or power fed via power electronic interfaces (e.g. wind farms, solar PV and HVDC interconnections to other

systems), in addition to the changing nature of electrical loads [3]. Previous work in the literature [4] has investigated the effect of changing loads on system stability by repeating fault studies for different loading levels. As a consequence, there is value in articulating metrics that exploit theoretical, if simplified, descriptions of the system which can provide a deep understanding of the impact of a wide range of features of the network from parametric investigations. This can inform efforts to design strategies to mitigate possible instabilities in the system.

In the recent literature, alternative methodologies have been used to study stability when modelling a power system using the so-called swing equations [1], [5]. These include synchronisation [6], non-linear dynamics [7], bifurcation theory [8], passivity-based methods [9] and the computation of basins of attraction [10]. Direct methods [11] cast the swing equations in an energetic framework to provide a critical energy boundary for the whole system during a fault. Despite the difficulty of including non-negligible transfer conductances in direct methods [12], their advantages include the possible estimation of an analytical stability boundary and relatively quick computation. Also, they require no need for further simplifications of a power system beyond the swing equation model and they can be applied to any system that can be parametrised. The system operator can use this analytical stability metric for initial safety checks and to assess the stability margins of the system once a fault has been cleared.

One of the drawbacks of the direct methods is that it is difficult to predict when the system energy will cross the critical energy boundary because of the non-linear nature of the system dynamics. So-called fault trajectory sensitivity techniques [13]–[15] have been proposed to consider the effect of parameters on stability by linearising about the trajectory of a fault in state space with respect to a given parameter. Furthermore, a method for computing a so-called ‘direct CCT’ has been proposed [16] which is based on linearising the power system model about a specific fault trajectory with respect to the system energy itself. An estimate of the CCT is then found by extrapolation. To our knowledge there is limited research on an analytic CCT metric for a network of synchronous generators [17]–[19] and an analytic metric that permits parametric investigations is only available for induction generators [20]. However, it is known that the ‘boundary of stability region-based controlling unstable equilibrium point’ (BCU) method [11] can be used for investigating stability sensitivities under

L. Roberts, A. Champneys and M. di Bernardo are in the Department of Engineering Mathematics, University of Bristol, UK. e-mail: lewis.roberts@bristol.ac.uk. M. di Bernardo is also with the Department of Electrical Engineering and ICT, University of Naples Federico II, Italy.

K. Bell is the ScottishPower Professor of Smart Grids at the University of Strathclyde, Glasgow UK.

the variation of system parameters [21].

The aim of this paper is to propose a new analytic expression to approximate the CCT of a fault. This estimate is derived by recasting the energetic metric used in the direct methods in terms of a metric in time by simplifying the energy functions and the dynamics during a fault. As is true for direct methods in general, our metric can serve as a lower bound to the true CCT for lossless power systems (or for power networks with small transfer conductances [22]) and can be applied to systems suffering a large fault at any location on a network. The purpose of our metric is to capture trends in stability as system parameters are varied. This is especially important now as power systems worldwide are undergoing the most fundamental changes experienced for many decades, largely because of transitions to renewable energy but also because of the increasing utilisation of power electronics which changes the interaction between the electrical and mechanical aspects of the system on both the generation and load sides. Rather than replacing existing and well-trusted power stability assessment methods used by transmission system operators, primarily full time domain simulation and use of concepts such as critical clearing time, in order to explore some of the possible impacts of these changes and illustrate the value of some potential new metrics, the investigations in this paper are based on aggregated or clustered power networks. (See [2, Chapter 14] for aggregation techniques.) Also, aggregation of networks have also been shown to be useful for transient stability assessments [23], [24].

In general, a power network's topology changes from its original structure when a fault is cleared. This is generally due to some switching action that isolates the region of the network that suffers the fault. Choosing the best strategy to quickly identify a need for and carry out this action is a crucial step in maintaining the stability and synchronisation of a power system. There is some uncertainty regarding the success and speed of protection actions, and, as a consequence, power flows may need to be restricted and more expensive, or higher carbon, power sources utilised. We argue that choices both in operation and the design of the system and its control can be facilitated by parameter investigations of power system stability models such as the swing equation and applying quick but effective stability metrics to illustrate the effect of a given parameter value change. A rigorous study of the strategies available to the system operator could be provided in-part by the continuous variation of model parameters, which could possibly uncover optimal parameter values to maximise stability at the design stage or on-line. The analytic CCT metric derived in this paper is able to capture sensitivities in stability of a given fault as a network parameter is varied. In particular, this paper studies the effect of a load parameter on the stability of a given fault in an aggregated network.

The rest of this paper is organised as follows: In Section II we formulate a CCT estimate denoted τ_H (where the subscript 'H' signifies 'Hamiltonian') using direct methods and introduce the aggregate network used to conduct our investigations, the two-machine infinite bus (TMIB) network. By considering polynomial approximations of τ_H we derive an analytic CCT metric denoted τ_A (where the subscript 'A'

signifies 'analytic') in Section III. A parametric investigation of the effect on stability of different loadings on an aggregated network given a particular fault is presented in Section IV and finally, conclusions are drawn in Section V together with suggestions for future work.

II. FAULT ANALYSIS USING ENERGY FUNCTIONS

A. Model description

We consider the classic swing equation model [1], [2] to describe the stability effects of transient faults on a power system with synchronous generation. The generators are modelled as voltage sources behind reactances and the loads on the network are of constant impedance. In general, generators have small losses due to damping [25] so without loss of generality we assume zero damping for generators. This model can be written as a set of coupled one-dimensional ordinary differential equations (ODEs), which describe the dynamics of the rotor angles of each synchronous generator $i \in \{1, \dots, n\}$ in a network by considering Newton's second law of dynamics. In vector form the equation is

$$\dot{\mathbf{x}} = \mathbf{F}(\mathbf{x}), \quad (1)$$

where

$$\mathbf{x} = \begin{pmatrix} \boldsymbol{\delta} \\ \boldsymbol{\omega} \end{pmatrix}$$

and

$$\mathbf{F} \left(\begin{pmatrix} \boldsymbol{\delta} \\ \boldsymbol{\omega} \end{pmatrix} \right) = \begin{pmatrix} \boldsymbol{\omega} \\ \mathbf{A}(\boldsymbol{\delta}) \end{pmatrix}.$$

The vectors $\boldsymbol{\delta} = [\delta_1, \dots, \delta_n]^T$ and $\boldsymbol{\omega} = [\omega_1, \dots, \omega_n]^T$ are the generator rotor angles and angular speeds respectively, and the elements of the vector function $\mathbf{A}(\boldsymbol{\delta})$ are

$$A_i(\boldsymbol{\delta}) = \frac{1}{M_i} (P_{mi} - P_{ei}(\boldsymbol{\delta})),$$

where $M_i = \frac{2H_i}{\omega_0}$ is a lumped parameter, $\omega_0 = 2\pi f$ (where f is the grid frequency: 50 Hz in Europe), H_i is the inertia constant, P_{mi} is the mechanical power input and $P_{ei}(\boldsymbol{\delta})$ is the electrical power output.

The loads on the power system are assumed to be constant impedance loads such that Kron reduction [26] can be applied to the network. Therefore, the swing equations describe the dynamics of a reduced network comprising of constant voltage sources connected through a network of impedances [2]. The total power consumed by conductive loads at generator i is given by

$$P_i(\boldsymbol{\delta}) = E_i^2 G_{ii} + \sum_{k \neq i}^n |E_i| |E_k| G_{ik} \cos(\delta_i - \delta_k), \quad (2)$$

where $E_i = |E_i| e^{j\delta_i}$ is the internal voltage of generator i ($|E_i|$ assumed constant), G_{ik} is the conductance between generators i and k and G_{ii} is the shunt conductance at bus i . The total electric power leaving generator i is

$$P_{ei}(\boldsymbol{\delta}) = P_i(\boldsymbol{\delta}) + \sum_{k \neq i}^n \bar{P}_{ik} \sin(\delta_i - \delta_k), \quad (3)$$

where $\bar{P}_{ik} = |E_i||E_k|B_{ik}$ is the maximum active power flow between generators i and k and B_{ik} is the susceptance of the network connection between node i and node k . The admittances $Y_{ik} = G_{ik} + jB_{ik}$ are the elements of the (symmetric) reduced bus admittance matrix $\mathbf{Y}_{\text{red}} \in \mathbb{C}^{n \times n}$, which is computed by performing Kron reduction on the full bus matrix $\mathbf{Y}_{\text{BUS}}$. The full bus matrix contains the complete topology and load distribution (including the synchronous reactance) of a power network with n synchronous generators.

A stationary point of the system (1) solves the equation $\mathbf{F}(\mathbf{x}) = \mathbf{0}$ (where $\mathbf{0}$ is a column vector of all zeros) and is denoted $\mathbf{x}^* = [\delta^{*T}; \omega^{*T}]^T$. A solution for (1) starting from initial conditions $\mathbf{x}(0)$ is written generically as

$$\mathbf{x}(t) = \Phi(t; \mathbf{x}(0)), \quad t \geq 0. \quad (4)$$

B. Fault analysis

1) *Stability analysis of transient faults:* The objective of transient fault analysis is to investigate whether a system will remain stable once a fault has been cleared and, ideally, no further action from the system operator would be required. We assume, without loss of generality, that the moment a power system suffers a short-circuit is at time $t = 0$ and the fault is cleared at time t_{cl} . These two points in time define three distinct regimes in order to analyse the dynamics of a fault on a power system. These are (i) $t < 0$ (*pre-fault*), (ii) $0 \leq t < t_{\text{cl}}$ (*fault-on*) and (iii) $t \geq t_{\text{cl}}$ (*post-fault*).

The fault analysis method in [25, Chapter 2] (recently summarised in [27]) for power networks with constant impedance loads, is employed in this paper. Each regime has a different bus matrix $\mathbf{Y}_{\text{BUS}}$ (and therefore reduced admittance matrix $\mathbf{Y}_{\text{red}}$) which will change the values of the parameters G_{ii} , G_{ik} and B_{ik} for all i, k in the vector function (1). Therefore, three separate sets of equations of the form (1) are required to model the power system for all time given by

$$\dot{\mathbf{x}} = \begin{cases} \mathbf{F}_{\text{pre}}(\mathbf{x}) & t < 0 \\ \mathbf{F}_{\text{on}}(\mathbf{x}) & 0 \leq t < t_{\text{cl}} \\ \mathbf{F}_{\text{post}}(\mathbf{x}) & t \geq t_{\text{cl}} \end{cases}, \quad (5)$$

where the labels ‘pre’, ‘on’ and ‘post’ refer to the parameter values for the system in regimes (i), (ii) and (iii) respectively. Pre-fault, a power system is assumed to be balanced and therefore we assume that (5) is located at a stable (‘s’) equilibrium point

$$\mathbf{x}_{\text{pre}}^s = \begin{pmatrix} \delta_{\text{pre}}^s \\ \mathbf{0} \end{pmatrix}$$

for $t < 0$ where $|\delta_{\text{pre},i}^s - \delta_{\text{pre},k}^s| < \pi/2$ for all i, k . The dynamics for $t \geq 0$ are given by

$$\mathbf{x}_{\text{on}}(t) = \Phi_{\text{on}}(t; \mathbf{x}_{\text{on}}(0) = \mathbf{x}_{\text{pre}}^s), \quad 0 \leq t < t_{\text{cl}} \quad (6)$$

during the fault and

$$\mathbf{x}_{\text{post}}(t) = \Phi_{\text{post}}(t; \mathbf{x}_{\text{post}}(0) = \mathbf{x}_{\text{on}}(t_{\text{cl}})), \quad t \geq t_{\text{cl}} \quad (7)$$

after the fault. The true CCT, denoted τ , is defined as the maximum clearing time such that a ‘first swing’ is still observed in the post-fault trajectory [25] and it is found algorithmically using power systems software packages.

2) *A CCT approximation using energetic methods:* In general, a conservative metric for the local stability of systems of the form (1) can be found by constructing a suitable Lyapunov function. Direct methods use so-called energy functions [5], which can also serve as Lyapunov functions, to measure the global stability of such systems. A stability boundary is constructed in terms of a critical system energy $\mathcal{E}_c$ in the post-fault regime and a power system is classified as unstable when the total system energy surpasses this critical energy.

The total system energy can be measured when a power system is modelled as a Hamiltonian system. However, the power consumed by the loads $P_i(\delta)$ is a path-dependent quantity [5] and cannot be modelled exactly by a conservative system. The survey paper [28] collects numerous attempts that have been used to approximate this term so that an appropriate Hamiltonian system can be used. One of the accepted techniques [2, p. 231] models the power consumed by the loads as a constant term given by

$$P_{ai} = P_i(\delta^s), \quad (8)$$

where the point $\mathbf{x}^s = [\delta^{sT}, \mathbf{0}^T]^T$ is a stable stationary point in the post-fault regime which solves $\mathbf{F}_{\text{post}}(\mathbf{x}^s) = \mathbf{0}$ with $|\delta_i^s - \delta_k^s| < \pi/2$ for all i, k . The dynamics of a power system with assumption (8) employed can be written as

$$\dot{\mathbf{x}} = \hat{\mathbf{F}}(\mathbf{x}, \mathbf{x}^s), \quad (9)$$

where terms depending on the conductive parts of loads are isolated to obtain the vector function $\hat{\mathbf{F}}(\mathbf{x}, \mathbf{x}^s)$. This function has a similar structure as in (1) where

$$\hat{\mathbf{F}}\left(\begin{pmatrix} \delta \\ \omega \end{pmatrix}, \begin{pmatrix} \delta^s \\ \mathbf{0} \end{pmatrix}\right) = \begin{pmatrix} \omega \\ \hat{\mathbf{A}}(\delta, \delta^s) \end{pmatrix},$$

and the elements of the vector $\hat{\mathbf{A}}(\delta, \delta^s)$ are given by

$$\hat{A}_i(\delta, \delta^s) = \frac{1}{M_i} \left(P_{mi} - \hat{P}_{ei}(\delta, \delta^s) \right),$$

with

$$\hat{P}_{ei}(\delta, \delta^s) = P_i(\delta^s) + \sum_{k \neq i}^n \bar{P}_{ik} \sin(\delta_i - \delta_k).$$

The Hamiltonian function

$$\mathcal{H}(\mathbf{x}) = \mathcal{E}_{\text{kin}}(\omega) + \mathcal{E}_{\text{pot}}(\delta), \quad (10)$$

quantifies the post-fault system energy for a system of the form (9) and is the sum of the kinetic energy $\mathcal{E}_{\text{kin}}(\omega)$ and the potential energy $\mathcal{E}_{\text{pot}}(\delta)$ for a power system with n generators where

$$\mathcal{E}_{\text{kin}}(\omega) = \sum_{i=1}^n \frac{1}{2} M_i \omega_i^2, \quad (11)$$

and

$$\mathcal{E}_{\text{pot}}(\delta) = - \sum_{i=1}^n (P_{mi} - P_{ai}) \delta_i - \sum_{\substack{i=1 \\ k>i}}^n \bar{P}_{ik} \cos(\delta_i - \delta_k). \quad (12)$$

An approximation of the CCT, denoted τ_H can be found by integrating the dynamics of the system during a fault until the system energy reaches the critical boundary $\mathcal{E}_c$ (which will be

computed later). More specifically, such an estimate can be obtained by observing the first instance that the Hamiltonian

$$\mathcal{H}(\mathbf{x}_{\text{on}}(t)) = \mathcal{E}_c, \quad (13)$$

for $t > 0$ where, in general, the energy difference

$$\Delta\mathcal{H}_{\text{max}} := \mathcal{E}_c - \mathcal{H}(\mathbf{x}_{\text{pre}}^s), \quad (14)$$

is positive for a suitably chosen post-fault network. Note that, the power system during the fault is not modelled as a Hamiltonian system. The CCT approximation τ_H is much faster to compute than the traditional CCT because the dynamics of the post-fault system (7) do not need to be computed.

The so-called *closest UEP* (unstable equilibrium point) method [11] is used to find the critical system energy $\mathcal{E}_c$ in this work. Although it is the most conservative method (compared to the controlling UEP method or the potential energy boundary surface method [11]) it is the simplest method that can be applied to any power system without considering the specific fault that a system suffers. In the presence of large linear loads in the network, the use of direct methods might lead to overestimates of the actual stability boundary [29] however, the intention is to study the effect of stability trends, so the closest UEP serves as an adequate method to capture the system energy for initial parametric studies. The accuracy of the stability boundary can be improved by using the controlling UEP and the BCU method [11], which is an efficient way to find this point.

The critical energy boundary computed by the closest UEP method is defined as

$$\mathcal{E}_c = \mathcal{E}_{\text{pot}}(\delta_c^u) = \min\{\mathcal{E}_{\text{pot}}(\delta_1^u), \dots, \mathcal{E}_{\text{pot}}(\delta_m^u)\}. \quad (15)$$

The point $\mathbf{x}_c^u \in \mathcal{S}$ is the so-called closest UEP where

$$\mathcal{S} = \{\mathbf{x}_1^u, \dots, \mathbf{x}_m^u\} \quad (16)$$

is the set of all ‘type-1’ [11] unstable equilibria of (9) where

$$\mathbf{x}_i^u = \begin{pmatrix} \delta_i^u \\ \mathbf{0} \end{pmatrix}.$$

C. An aggregate network

In order to study trends in stability under parametric variations, the dynamics of each generator in a network can be grouped into synchronous regions according to the electrical distance between individual generators. Previous studies [30]–[32] have used an aggregate power network model to study the global dynamics of a power system. Typically, the models presented in these references study the GB power network using a three bus network with the inertia of one machine much larger than the other two. These models lend themselves well to be studied using a so-called two machine infinite bus (TMIB) system. This network structure has been previously studied in [11], [33]–[35]. The ODE in the form (9) for this

Fig. 1. (colour online) An illustration of the Hamiltonian (10) for a TMIB system in the manifold where $\omega_1 = \omega_2 = 0$. Equation (12) is plotted as a surface in 3-dimensions and the energy difference $\Delta\mathcal{H}_{\text{max}}$ is given exactly by the difference in energy between the level sets $\mathcal{E}_{\text{pot}}(\delta_1, \delta_2) = \mathcal{E}_c = \mathcal{E}_{\text{pot}}(\delta_c^u)$ and $\mathcal{E}_{\text{pot}}(\delta_1, \delta_2) = \mathcal{E}_{\text{pot}}(\delta_{\text{pre}}^s)$ where $\mathbf{x}_c^u = [\delta_c^u, \mathbf{0}^T]^T$ is the closest UEP (found using condition (15)), $\mathbf{x}_{\text{pre}}^s = [\delta_{\text{pre}}^s, \mathbf{0}^T]^T$ is the pre-fault stable equilibrium point and $\mathbf{x}^s = [\delta^s, \mathbf{0}^T]^T$ is the stable post-fault equilibrium point.

system is given by

$$\begin{aligned} \dot{\delta}_1 &= \omega_1 \\ \dot{\delta}_2 &= \omega_2 \\ \dot{\omega}_1 &= \frac{1}{M_1} [(P_{m1} - P_{a1}) - \bar{P}_{13} \sin(\delta_1) - \bar{P}_{12} \sin(\delta_1 - \delta_2)] \\ \dot{\omega}_2 &= \frac{1}{M_2} [(P_{m2} - P_{a2}) - \bar{P}_{23} \sin(\delta_2) - \bar{P}_{12} \sin(\delta_2 - \delta_1)] \end{aligned} \quad (17)$$

where we have employed assumption (8) to get a conservative system. The infinite bus models the dynamics of a large section of a network as a generator with infinite inertia and has constant internal voltage E_3 and rotor angle δ_3 , which without loss of generality is set to $\delta_3 = 0$. For illustrative purposes, the potential energy (12) for this system is plotted as a surface in 3-dimensions in Fig. 1. The critical energy boundary $\mathcal{E}_c = \mathcal{H}(\mathbf{x}_c^u) = \mathcal{E}_{\text{pot}}(\delta_c^u)$ and the initial energy $\mathcal{H}(\mathbf{x}_{\text{pre}}^s) = \mathcal{E}_{\text{pot}}(\delta_{\text{pre}}^s)$ are plotted as level sets on the surface.

III. AN ANALYTIC STABILITY METRIC

An analytic stability metric, denoted τ_A , which is purely a function of network parameters, is presented and derived here. The metric is formulated by considering (13) and approximating both the Hamiltonian (10) and the fault trajectory (6) in this equation as polynomial functions of rotor angles and time respectively. During a fault, it is assumed that the governor control systems for the mechanical input power P_{mi} in each generator are not able to act quickly enough to change the parameter value during (or immediately after) the fault; therefore $P_{mi}^{\text{pre}} = P_{mi}^{\text{on}} = P_{mi}$ throughout this analysis. In addition, the dynamics of the rotor angles during the fault are approximated as constant but different accelerations. Although some of these approximations may seem cumbersome, and will detract significantly from the true dynamics of the system, they

are valid in the limit as the CCT tends to zero. Therefore, we assume that for small values of the CCT these approximations can be assumed to capture the dynamics of a power system modelled as a Hamiltonian system. In addition, we remind the reader that this metric is designed to provide an instant illustration of the stability of a power system under the variation of a chosen parameter. In the next section, we demonstrate how our analytic metric can be used to find approximate regions for values of a load parameter in an aggregate network that improves stability for a given fault on the network.

Metric formulation

An analytical expression to approximate the CCT for three-phase to ground faults close to a given bus (on a balanced system such that it can be modelled by means of a single phase equivalent) can be found by adapting the energetic framework for the CCT presented in Section II-B2. The expression (13) is altered such that we solve

$$h_{\text{alt}}(t) = \mathcal{E}_c, \quad (18)$$

where $h_{\text{alt}}(t)$ is a polynomial function such that

$$h_{\text{alt}}(t) \approx h(t), \quad (19)$$

with initial condition

$$h_{\text{alt}}(0) = h(0), \quad (20)$$

and $h(t) \equiv \mathcal{H}(\mathbf{x}_{\text{on}}(t))$.

In order to construct the function $h_{\text{alt}}(t)$, we first approximate the Hamiltonian function as a polynomial function of the rotor angles, denoted $h_{\text{alt}}(\delta_{\text{on}}(t))$. The kinetic term from the post-fault Hamiltonian function is removed by also modelling the dynamics during the fault as a Hamiltonian system. In general, there is no stable stationary point available during the fault so the power consumed by the conductive loads is approximated as a constant $P_{ai}^{\text{on}} = P_i^{\text{on}}(\delta_{\text{pre}}^s)$ such that the dynamics can be written in the form (9) to give

$$\dot{\mathbf{x}}_{\text{on}} = \hat{\mathbf{F}}_{\text{on}}(\mathbf{x}_{\text{on}}, \mathbf{x}_{\text{pre}}^s), \quad (21)$$

for $t \geq 0$ and $\mathcal{H}(\mathbf{x}_{\text{on}}) \leq \mathcal{E}_c$. The Hamiltonian during the fault is given by

$$\mathcal{H}_{\text{on}}(\mathbf{x}_{\text{on}}(t)) = \mathcal{H}_{\text{on}}(\mathbf{x}_{\text{pre}}^s). \quad (22)$$

In accordance with conservative systems, $\mathcal{H}_{\text{on}}(\mathbf{x}_{\text{pre}}^s)$ is a constant in time and this property is used to recast the expression for $\mathcal{H}(\mathbf{x}_{\text{on}}(t))$ in (13) by considering the trivial relation

$$\mathcal{H}(\mathbf{x}_{\text{on}}(t)) = \mathcal{H}(\mathbf{x}_{\text{on}}(t)) - \mathcal{H}_{\text{on}}(\mathbf{x}_{\text{on}}(t)) + \mathcal{H}_{\text{on}}(\mathbf{x}_{\text{pre}}^s), \quad (23)$$

resulting in the succinct expression

$$\begin{aligned} \mathcal{H}(\mathbf{x}_{\text{on}}(t)) &= \sum_{i=1}^n (P_{ai} - P_{ai}^{\text{on}}) \delta_{\text{on},i}(t) \\ &\quad - \sum_{\substack{i=1 \\ k>i}}^n (\bar{P}_{ik} - \bar{P}_{ik}^{\text{on}}) \cos(\delta_{\text{on},i}(t) - \delta_{\text{on},k}(t)) \\ &\quad + \mathcal{H}_{\text{on}}(\mathbf{x}_{\text{pre}}^s), \end{aligned} \quad (24)$$

which has no dependence on rotor speeds. The values of the parameters $\bar{P}_{ik}^{\text{on}}$, P_{ai}^{on} , $\bar{P}_{ik}$ and P_{ai} are found from the fault-on and post-fault reduced admittance matrices and the internal voltages.

A candidate function for $h_{\text{alt}}(\delta_{\text{on}}(t))$ can be found by replacing the cosine terms in (24) with the function

$$1 - \frac{1}{2} \Delta \delta_{\text{on},ik}^2(t) \approx \cos(\Delta \delta_{\text{on},ik}(t)),$$

for small $\Delta \delta_{\text{on},ik}(t) = \delta_{\text{on},i}(t) - \delta_{\text{on},k}(t)$. This substitution gives

$$\begin{aligned} h_{\text{alt}}(\delta_{\text{on}}(t)) &= \sum_{i=1}^n (P_{ai} - P_{ai}^{\text{on}}) \delta_{\text{on},i}(t) + \\ &\quad \sum_{\substack{i=1 \\ k>i}}^n (\bar{P}_{ik} - \bar{P}_{ik}^{\text{on}}) \left(1 - \frac{1}{2} \Delta \delta_{\text{on},ik}^2(t) \right) + \mathcal{H}_{\text{on}}(\mathbf{x}_{\text{pre}}^s) + C, \end{aligned} \quad (25)$$

where the constant C is found by applying the initial condition (20), i.e. $h_{\text{alt}}(\delta_{\text{on}}(0)) = \mathcal{H}(\mathbf{x}_{\text{pre}}^s)$, to (25). Therefore,

$$\begin{aligned} C &= - \sum_{i=1}^n (P_{ai} - P_{ai}^{\text{on}}) \delta_{\text{pre},i}^s + \\ &\quad - \sum_{\substack{i=1 \\ k>i}}^n (\bar{P}_{ik} - \bar{P}_{ik}^{\text{on}}) \left(1 - \frac{1}{2} \Delta \delta_{\text{pre},ik}^2 \right) - \mathcal{H}_{\text{on}}(\mathbf{x}_{\text{pre}}^s) + \mathcal{H}(\mathbf{x}_{\text{pre}}^s), \end{aligned} \quad (26)$$

where $\Delta \delta_{\text{pre},ik} = \Delta \delta_{\text{on},ik}(0)$ and (25) can be re-written as

$$\begin{aligned} h_{\text{alt}}(\delta_{\text{on}}(t)) &= \sum_{i=1}^n (P_{ai} - P_{ai}^{\text{on}}) (\delta_{\text{on},i}(t) - \delta_{\text{pre},i}^s) + \\ &\quad \sum_{\substack{i=1 \\ k>i}}^n \frac{(\bar{P}_{ik} - \bar{P}_{ik}^{\text{on}})}{2} (\Delta \delta_{\text{on},ik}^2(t) - \Delta \delta_{\text{pre},ik}^2) + \mathcal{H}(\mathbf{x}_{\text{pre}}^s), \end{aligned} \quad (27)$$

where the constant C is written explicitly.

In order to make (27) an explicit polynomial function of time, the fault trajectory must also be written as a polynomial function of time. In general, the dynamics during a fault are non-trivial [36] but in order for (18) to be analytically solvable for time, the rotor angle dynamics in (27) must have the form

$$\delta_{\text{on},i}(t) = \frac{1}{2} u_i t^2 + \delta_{\text{pre},i}^s, \quad (28)$$

where the initial condition $\dot{\delta}_{\text{on},i}(0) = 0$ holds for all i . An appropriate value for the acceleration u_i can be found by assuming that for small CCTs the rotor dynamics can be modelled as a constant acceleration equal to the initial rotor acceleration at $t = 0$. This is given by

$$\dot{\mathbf{x}}_{\text{on}} \approx \hat{\mathbf{F}}_{\text{on}}(\mathbf{x}_{\text{pre}}^s, \mathbf{x}_{\text{pre}}^s) = \begin{pmatrix} \omega \\ \hat{\mathbf{A}}_{\text{on}}(\delta_{\text{pre}}^s, \delta_{\text{pre}}^s) \end{pmatrix} = \begin{pmatrix} \omega \\ \mathbf{A}_{\text{on}}(\delta_{\text{pre}}^s) \end{pmatrix}, \quad (29)$$

for short fault times. From equation (29) the rotor accelerations $\ddot{\delta}_{\text{on},i} = u_i = A_{\text{on},i}(\delta_{\text{pre}}^s)$. By substituting expressions (28) for

the rotor angles into (27), the function

$$h_{\text{alt}}(t) = \mathcal{H}(\mathbf{x}_{\text{pre}}^s) + \sum_{i=1}^n (P_{ai} - P_{ai}^{\text{on}}) \frac{1}{2} u_i t^2 + \sum_{\substack{i=1 \\ k>i}}^n (\bar{P}_{ik} - \bar{P}_{ik}^{\text{on}}) \left(\frac{1}{8} u_{ik}^2 t^4 + \frac{1}{2} u_{ik} \Delta \delta_{\text{pre},ik} t^2 \right), \quad (30)$$

is a quadratic in t^2 where $u_{ik} = u_i - u_k$. Now (18) can be written as

$$\alpha t^4 + \beta t^2 - \gamma = 0, \quad (31)$$

where the coefficients

$$\begin{aligned} \alpha &= \sum_{\substack{i=1 \\ k>i}}^n \frac{1}{8} (\bar{P}_{ik} - \bar{P}_{ik}^{\text{on}}) u_{ik}^2, \\ \beta &= \sum_{\substack{i=1 \\ k>i}}^n \frac{1}{2} (\bar{P}_{ik} - \bar{P}_{ik}^{\text{on}}) u_{ik} \Delta \delta_{\text{pre},ik} + \\ &\quad \sum_{i=1}^n \frac{1}{2} (P_{ai} - P_{ai}^{\text{on}}) u_i, \\ \gamma &= \mathcal{E}_c - \mathcal{H}(\mathbf{x}_{\text{pre}}^s) = \Delta \mathcal{H}_{\text{max}} > 0 \end{aligned}$$

are functions of the power network parameters. The solution of (31) and thus the expression for our analytic CCT is given by

$$\tau_A = \left(\frac{-\beta \pm \sqrt{\beta^2 + 4\alpha\gamma}}{2\alpha} \right)^{\frac{1}{2}}. \quad (32)$$

The smallest real value of τ_A is used for a given set of parameters. A purely imaginary value for τ_A is produced if the discriminant $\beta^2 + 4\alpha\gamma < 0$ or if $\beta < 0$ and $\alpha < 0$. In the case where $\alpha < 0$ and $\beta > 0$ two positive roots are produced, otherwise there is one real root to (32). However, in general the parameter α is positive because the total electrical load of a network reduces during a fault and so it is reasonable to assume that $\bar{P}_{ik} > \bar{P}_{ik}^{\text{on}}$ for all i, k .

Figure 2 illustrates how the analytic CCT τ_A compares with the true CCT τ and the CCT estimate τ_H developed in Section II-B2.

IV. PARAMETRIC STABILITY ANALYSIS

A. Implementation details

The stability of a power network is not only dependent on the type or duration of a fault but also on the choice of system parameters. Optimal regions of parameter space that increase the stability of a power system can be identified by the variation of system parameters. Here, we investigate values for a load on a TMIB network which improve system stability for a given fault, by comparing the metrics τ_H and τ_A outlined in Sections II and III against the true CCT τ . The energy difference $\Delta \mathcal{H}_{\text{max}}$ is also compared against the temporal stability metrics.

In this study a 9 bus, 3 generator power network found in [25] is used, a schematic of this network is provided in Fig. 3. All parameter values for this network are taken from [25]. This network is adapted into a TMIB network by changing

Fig. 2. (colour online) This figure illustrates the definitions of the three CCT metrics in δ -space: (i) the true CCT τ is the maximum time a fault can remain on-line such that there is one full swing of the rotor angles post-fault; (ii) the CCT estimate τ_H is defined using the direct methods by solving (13) and in the figure it is where the fault trajectory (dashed line) intersects the level set $\mathcal{H}(\mathbf{x}) = \mathcal{E}_c$; (iii) the analytic CCT τ_A is the analytic metric derived in this paper. The analytic CCT is found by solving (18) where the fault-on and post-fault regimes are modelled as Hamiltonian systems. In δ -space (18) is given by an ellipse for a TMIB system and the fault trajectory (dotted line) is approximated using a constant but unique acceleration for each generator.

the generator with the largest inertia constant into an infinite bus. The specific fault we consider is a three-phase to ground fault close to bus 7 on the line connecting buses 5 and 7. The post fault network is identical to the pre-fault network except the line connecting buses 5 and 7 is switched out.

The variation of a load parameter in a power network will change one of the elements in the full bus admittance matrix $\mathbf{Y}_{\text{BUS}}$, but due to Kron reduction all the parameters in the reduced admittance matrix $\mathbf{Y}_{\text{red}}$ in each regime will change. Therefore, for each incremental change in the parameter we consider, a new fault study is required to find the CCT. In each fault study, the mechanical input powers for each generator are found by performing a pre-fault power flow for the system. The power flow is conducted using the same (small) rotor angles found in [25] for each incremental change in the parameter value to ensure that the network is initially in a stable state.

It is relatively quick to conduct a single fault study to find the true CCT τ . However, for each incremental change in a parameter, a new fault analysis is required to find the CCT. An analytic CCT τ_A has been developed to study trends in stability of power systems, which can be found instantly once the relevant parameter values for the model in (5) have been collected. For a given fault, system parameters can be varied continuously using an analytic CCT and this can provide an initial picture of stability that informs more detailed analysis.

All the stability metrics introduced in this paper, except for the true CCT τ , are dependent on a critical energy boundary

$\mathcal{E}_c$ which is dependent on the location of the closest UEP in this work. The position of the closest UEP will change under the variation of the loads and there are techniques developed in the literature to find these quickly [37]. However, we choose to use numerical continuation (previously applied to power systems in [38]) to illustrate interesting features of the closest UEP under the variation of loads. The continuation method we use is well suited to continue UEPs once detected, and is well established in theory to be closely related to other path following and homotopy methods [39]. Recently, a sophisticated version of such an algorithm has been developed with the specific aim of finding critical UEPs [40], [41]. The stationary points of a TMIB system, modelled by the ODEs in (17), are located using the continuation software AUTO¹ as a load parameter is varied. There is no rigorous proof provided in this paper that all the possible unstable equilibria on the stability boundary of a stable equilibrium point can be found from the solution branches from numerical continuation. However, no other solutions were found for this system when performing an exhaustive search over state space using the root finding algorithm fsolve from the Scipy² library in the Python³ programming language. Therefore, without further analysis, it is assumed that only in a TMIB system can all the necessary stationary points be found using this continuation method.

The stationary points for each value of the continuation parameters in Fig. 4a and Fig. 5a are obtained by the following method: A stable stationary point denoted by $\mathbf{x}^s = [\delta_1^s, \delta_2^s, \omega_1 = 0, \omega_2 = 0]$ that solves the post fault equation $\mathbf{F}_{\text{post}}(\mathbf{x}^s) = \mathbf{0}$ (where $n = 2$ and $\delta_3 = 0$) is found using the root finding algorithm fsolve, where $|\delta_i^s - \delta_k^s| \in \frac{\pi}{2}$ for $i = 1, 2$. This point belongs to the lower branch (blue squares) of the bifurcation diagram in Figs 4a and 5a. The other (unstable) equilibria on the boundary of the stability region of the stable equilibrium point $\mathbf{x}^s$ which satisfy $\hat{\mathbf{F}}_{\text{post}}(\mathbf{x}) = \mathbf{0}$ are found by numerical continuation of the element B_{12} from the reduced admittance matrix $\mathbf{Y}_{\text{red}}$. Once the continuation branches are found, the stationary points at the value of B_{12} found in $\mathbf{Y}_{\text{red}}$ are recorded. The local stability of the stationary points obtained are found by computing the eigenvalues of the Jacobian matrix for the system (17). The stability of the solution branches in Figs 4a and 5a are stated in terms of the number of eigenvalues with real part greater than zero which can be found in the figure caption of Fig 4.

B. Results

The size and nature of loads on actual power systems can vary over time and, in respect of the susceptible part, can be modified by the addition of reactive compensation. As a consequence, the conductive and susceptible parts of load C (denoted G_C and B_C respectively) of the network in Fig. 3 are investigated by varying one part while maintaining the other constant at its original value. In Figs. 4a and 5a the domains of the parameters B_C and G_C respectively are constrained by two conditions: (i) the energy margin $\Delta\mathcal{H}_{\text{max}} \geq 0$ and (ii)

Fig. 3. Schematic of the full test network found in [25] where all parameter values can be found in the reference. Buses 1 and 2 are (P, V) buses with synchronous generators attached. Bus 1 is a (V, θ) infinite bus. All other buses are (P, Q) buses with buses 5, 6 and 8 also possessing shunt loads with the original values $Y_A = 1.261 - 0.2634j$, $Y_B = 0.8777 - 0.0346j$ and $Y_C = 0.969 - 0.1601j$. The fault we consider occurs on the line 5-7 close to bus 7, and the post fault network has line 5-7 switched out.

that the synchronous machines are operating as generators in the pre-fault power flow, i.e. $P_{m1} > 0$ and $P_{m2} > 0$. There is an additional constraint in Fig. 4 where only positive values of conductance are explored.

The critical energy change for the system $\Delta\mathcal{H}_{\text{max}}$ (black line), the CCT estimate τ_H (blue line) and the analytic CCT τ_A (red line) are plotted as functions of the continuation parameters in the lower panels of Figs. 4 and 5. In addition, the true CCT τ (green line) is plotted using a simple algorithm that uses a binary search to find the maximum duration which the fault can be left on-line such that the rotor angles have one full swing together before they diverge. There are two different scales to facilitate observing the functions in the lower panels of Figs. 4 and 5: the energy change $\Delta\mathcal{H}_{\text{max}}$ should be read using the right-hand y-axis labels and the three time metrics should be read using the left-hand y-axis labels as indicated in the figures.

In Fig. 4 the dependence of the system stability, for the fault we consider, on the conductance G_C is studied as the susceptance B_C is held constant. In Fig. 4a there is a discontinuity in the closest UEP (thick line) at $G_C = 6.26$ (vertical dotted line) which is located between two pairs of fold points at $G_C = 2.95$ and $G_C = 8.56$. (See [42] for an explanation of fold points). In Fig. 4b there is a discontinuous change in the gradient of $\Delta\mathcal{H}_{\text{max}}$ which coincides with the discontinuity at $G_C = 6.26$, but the maximum point for $\Delta\mathcal{H}_{\text{max}}$ at $G_C = 4.0$ does not coincide with the other discontinuity in the closest UEP, nor any other points of significance in Fig. 4a. The analytic CCT τ_A is observed to approximate the CCT estimate τ_H very well as the load parameter G_C is varied. However, the energetic techniques used to find τ_A and τ_H have resulted in non-conservative estimates of the true CCT τ . This feature is a manifestation of the original issue with direct methods which concerns the dissipative term (2) at each bus in the reduced network. Direct

¹<http://indy.cs.concordia.ca/auto/>

²<http://docs.scipy.org/doc/>

³www.python.org

Fig. 4. (colour online) The continuation diagram in (a) plots the modulus of the stationary solutions $|\mathbf{x}^*|$ to the ODE (17) as a function of the bifurcation parameter G_C with $B_C = -0.1601$ p.u. The stability of the solution branches are colour coded using the legend. The stability of each branch is given by the number of eigenvalues with positive real part; for branch segments A , B and C these are 0, 1 and 2 respectively. The thicker line indicates the closest UEP $|\mathbf{x}_c^u| = |\delta_c^u|$. In (b) the CCT metrics τ , τ_H and τ_A should be read using the left y-axis and the energy margin metric $\Delta\mathcal{H}_{\max}$ should be read using the right y-axis. Note that the values of τ_H and τ_A are very close together.

methods can be used for conservative stability assessments where the transfer conductances G_{ij} in the reduced network matrix $\mathbf{Y}_{\text{red}}$ are assumed to be small or zero [11], therefore the CCT estimate τ_H and the analytic CCT τ_A are strict lower bounds of the true CCT τ for networks with zero transfer conductances. However, even for a network with lossless lines, Kron reduction invokes complications in which a shunt load conductance in the full bus admittance matrix will increase the absolute values of G_{ij} in the reduced admittance matrix [12], [28]. In this case, an inaccurate assessment of critical clearing time for small loads (high conductances) is produced, but our analytic metric does capture the general trend in stability and its maximum value occurs for high loading of the network ($G_C = 0$), also observed in the true CCT τ . In addition, the greatest CCT as measured by all metrics for the fault we have considered is produced at $G_C = 0$. (This behaviour was found for all possible faults on the network under the variation of one of the loads A , B or C within an order of magnitude of its nominal value.) In general, a lower mechanical input power from each generator is required for lower network loadings and therefore the acceleration of the generator rotor

Fig. 5. (colour online) The continuation diagram in (a) plots the modulus of the stationary solutions $|\mathbf{x}^*|$ to the ODE (17) as a function of the bifurcation parameter B_C with the conductance of load C held constant at $G_C = 0.969$ p.u. The stability of the solution branches are colour coded using the legend in Fig. 4a and the stability information can be found in the caption of Fig. 4. The thicker line indicates the closest UEP $|\mathbf{x}_c^u| = |\delta_c^u|$. In (b) the CCT metrics τ , τ_H and τ_A should be read using the left y-axis and the energy margin metric $\Delta\mathcal{H}_{\max}$ should be read using the right y-axis. Note that the values of τ_H and τ_A are very close together.

angles is roughly proportional to the mechanical input power, assuming that the load of the network decreases during a fault. Therefore, there is more time for the rotors to reach a critical value where they begin to diverge.

In Fig. 5 the dependence of the system stability, for the fault we consider, on the susceptance B_C is studied as the conductance G_C is held constant. In Fig. 5a there is a discontinuity in the closest UEP (thick line) at $B_C = -4.80$ which is located between two fold points at $B_C = -5.78$ and $B_C = -3.62$. In Fig. 5b there is a discontinuous change in the gradient of $\Delta\mathcal{H}_{\max}$, τ_H and τ_A at the discontinuity in the closest UEP. The maximum of $\Delta\mathcal{H}_{\max}$ occurs at the highest value of susceptance plotted, which shows that the energy margin is not the best metric to quantify stability. The analytic CCT τ_A is very close to the CCT estimate τ_H as B_C is varied and are, again, overestimates due to the presence of non-negligible transfer conductances. The maximum points of τ_H and τ_A , both at $B_C = -5.75$ are very close to the closest UEP discontinuity, however the maximum point of the true CCT τ is lower, at $B_C = -8.2$. Despite this, the change in the true CCT as the susceptance B_C is varied is well captured by the CCT approximations, except in the region $[-8.2, -4.8]$

Fig. 6. (colour online) This figure illustrates the change to the energy boundary as the closest UEP changes position at the discontinuity $\hat{G}_C = 6.28$ (vertical dotted line) in Fig. 4a due to a change in the parameter G_C . The energy boundary is plotted in the manifold where $\omega_1 = \omega_2 = 0$ such that the boundary can be plotted by the level sets $\mathcal{E}_{\text{pot}}(\delta_1, \delta_2) = \mathcal{E}_c$. These level sets are plotted for conductance values (a) $G_C = 5.5 < \hat{G}_C$, (b) $G_C = \hat{G}_C$ and (c) $G_C = 6.6 > \hat{G}_C$. In each sub-figure, the stationary points are plotted using the same marker style found in the legend of Fig. 4a.

where the gradients are of different signs.

In Fig. 6 the change to the energy boundary $\mathcal{H}(\mathbf{x}) = \mathcal{E}_c$ (plotted in the manifold where $\omega_1 = \omega_2 = 0$) due to the discontinuity in the location of the closest UEP under the variation of the conductance of load C G_C (illustrated in Fig. 4a) is plotted. In this manifold, the energy boundary is plotted as the level set $\mathcal{E}_{\text{pot}}(\delta_1, \delta_2) = \mathcal{E}_c$ (black line) for conductance values (a) $G_C = 5.5 < \hat{G}_C$, (b) $G_C = \hat{G}_C$ and (c) $G_C = 6.6 > \hat{G}_C$ where the discontinuity occurs at $\hat{G}_C = 6.28$. In each sub-figure of Fig. 6 the stationary points of (17) are plotted using the same marker style found in the legend of Fig. 4a and the level set is observed to intersect the closest UEP.

In Fig. 7, the susceptance B_C is varied in a network with small load conductances and it is observed that τ_A and τ_H are lower bounds to τ when compared to the results in Fig. 5. This result demonstrates that direct methods are conservative estimates for small transfer conductances. In this case, small transfer conductances are achieved by decreasing the conductances of all loads by an order of magnitude compared to their original values. However, we note that the analytic CCT performs well as an indicator of the general trends in CCT as B_C is varied, despite whether it is an over or underestimate of the true CCT.

It is observed that the system stability can benefit by setting the susceptance of load C to the optimum susceptance as measured by the analytic CCT because these susceptance values can be evaluated without the need for numerical integration. The true CCT using the parameter values as stated in [25] is $\tau = 0.107\text{s}$. From Table I, a network operating at the optimum value of susceptance $B_C = -8.2$ would give a true CCT of $\tau(B_C = -8.2) = 0.170\text{s}$ and this is an increase of 0.63s . However, the value of the true CCT at the optimum

Fig. 7. (colour online) This figure is identical to the results presented in Fig. 5 except that the conductive parts of the loads in the network are changed to be small values. This is done to show that the analytical CCT serves a lower bound for networks with small transfer conductances in the reduced admittance matrix and this is achieved by having small conductive parts to the loads. The values are $G_A = G_B = G_C = 0.1$ for loads A, B and C respectively.

Optimum susceptance	$\tau(\cdot)$	$\tau_A(\cdot)$
$\arg \max(\tau, B_C) = -8.20$	0.170s	N/A
$\arg \max(\tau_A, B_C) = -5.75$	0.158s	0.203s

TABLE I
MAXIMUM CCT VALUES AT OPTIMUM SUSCEPTANCE VALUES FOR LOAD C. THE ORIGINAL TRUE CCT AT THE PARAMETER VALUES GIVEN IN [25] IS $\tau = 0.107\text{s}$

Optimum susceptance	$\tau(\cdot)$	$\tau_A(\cdot)$
$\arg \max(\tau, B_B) = -3.10$	0.124s	N/A
$\arg \max(\tau_A, B_B) = -1.20$	0.120s	0.157s

TABLE II
MAXIMUM CCT VALUES AT OPTIMUM SUSCEPTANCE VALUES FOR LOAD B. THE ORIGINAL TRUE CCT AT THE PARAMETER VALUES GIVEN IN [25] IS $\tau = 0.107\text{s}$

value of susceptance as measured by the analytic CCT is $\tau(B_C = -5.75) = 0.158\text{s}$ which is a smaller but significant increase of 0.51s . The advantage of using the optimum values of susceptance as measured by the analytic CCT is that an

improved susceptance value is known as soon as the relevant network parameters have been collected. The variation of susceptible loads can represent, for example, a network owner's installation of reactive compensation, a measure that is known to contribute not only to voltage regulation but also transient stability [43].

The continuation of the susceptible part of load B B_B (with the other loads at original values) is considered for the same fault at bus 7 and the results are given in Table II. The results for load A are not included in the tables because there was no maximum point for CCT found as the susceptible part of load A B_A was varied and the trends in stability were similar to the lower panel of Fig 4. The largest CCT was found for $B_A = -13.9$ which is the lowest value of susceptance for which the mechanical input powers of the synchronous generators P_{m1} and P_{m2} are both greater than zero.

V. DISCUSSION

In this paper we have presented a new analytic CCT metric τ_A designed to be able to capture trends in the true CCT τ as a system parameter is varied. Specifically the effects of the conductive and susceptible parts of a load parameter on the network were considered, given a fault on the network. The analytic CCT metric τ_A was formulated by taking a polynomial approximation of the CCT estimate τ_H developed from direct methods and it is found that despite the simplicity of the formula, the analytic CCT is a good approximation to τ_H for short times. Given the difficulty for all direct methods to incorporate power networks with non-negligible transfer conductances, it was expected that the two approximating metrics τ_H and τ_A would not perform well as good estimates to the true CCT τ . However, the two approximating metrics performed much better as indicators of trends in stability as a load parameter was varied. In addition, the results in this paper were generated for an aggregate power network, the two-machine infinite-bus, where studies on aggregated networks [30], [32] are generally conducted to analyse global trends of a network with a much larger number of generators, buses and loads. The approximating CCT metrics are valid in principle for power systems with or without an infinite bus and numerical results will be extended to alternative networks without an infinite bus in future work.

Direct methods were chosen to formulate the CCT approximations because of their ability to construct a well-defined stability boundary in terms of a critical energy $\mathcal{E}_c$. However, this stability boundary is dependent on finding a critical UEP of the system that can be used to approximate the energy when a power system is modelled as a Hamiltonian system. In this paper, the closest UEP was chosen to compute the energy boundary because it is valid for any fault on a power system. A more accurate method to quantify the system energy uses the controlling UEP [44], which is dependent on the fault a network suffers and can be found using the BCU method [11], [45]; the limitations of which are discussed in [33]. For the TMIB network it was possible to find all UEPs on the stability boundary of an appropriate stable equilibrium point of the system under the variation of a load parameter

using numerical continuation methods. There was no attempt to formally prove that all UEPs are captured, but an exhaustive algorithmic search was used to confirm this. However, the scalability of this approach is limited because the number of equilibria increases as the system size increases [46] and it is increasingly difficult to identify the critical UEP and this is a significant area of research in itself [37], [47]. In addition, the positions of the equilibria have to be found for each incremental change of a load parameter. This is another reason the analysis in this paper was limited to study trends on an aggregated power network with a small number of generators.

The most general use for the analytic CCT proposed in this paper is to capture stability trends under the variation of a network or generator parameter and we have specifically studied the effect of varying loads. A more specific suggested use for the metric is to locate regions of parameter space that will improve the system stability in terms of CCT. For the fault studied in our analysis of the TMIB network, we found that the optimum value of CCT for the conductive part of load C is $G_C = 0$ for non-negative conductance values and that the CCT decreases as G_C increases. One interpretation of this result is that a high penetration of linear power sources, local to the point of power consumption has the effect of increasing system stability, but research in [4] suggests that the effect on system dynamics is dependent on the specific technologies in the generator. More promising results were found for the variation of the susceptible part of a load under constant conductance.

Improved values for load susceptances to increase system stability can be found using the analytical metric proposed in this paper and shunt compensation strategies [48]–[50] can be used to shift load susceptances to desired values. An optimal value of susceptance that maximises the CCT was identified in all three temporal metrics, however the optimal value of susceptance that maximises τ was different to the value that maximises both τ_H and τ_A . It was found that true CCT would be improved by 47% if the optimum susceptance loading for load C as measured by the analytic CCT was used instead of the original value of susceptance for this load. Given the quick assessment provided by an analytic CCT, an exhaustive study of all three-phase to ground faults on a network with their respective post-fault clearing strategies could be performed under a continuous range of loading conditions without having to do any formal fault study. Future research would then be required to test mathematical optimisation methods designed to find optimal loading distributions that improve the stability of the power system as measured by the CCT.

Despite its drawbacks, our analytic stability metric has the potential to inform optimal fault management strategies to improve system stability through parametric investigation. Another route for instability can arise from the variation of a damping parameter and our metric cannot be used to assess instabilities though global bifurcations [51] due to assuming zero damping for each generator. However, different tools [52] are required to analyse these instabilities depending on the method used to model the damping.

The key advantage of our metric is that it can be computed instantly once all the system parameter values for the pre-

fault, fault-on and post-fault systems have been collected. This feature of stability metrics could be of use due to system dynamics becoming more unpredictable from the changing nature of loads [3] and generation [53]–[55] under the constraint of limited power flow through transmission lines. Particularly, investigations on the effect of low inertia on power system stability [31], [56] can potentially benefit and this is an area of future work. Furthermore, optimisation techniques could be applied to analytic metrics to find regions in parameter space that increase power system stability in terms of CCT.

REFERENCES

- [1] P. S. Kundur, *Power System Stability*. McGraw-Hill, 1994.
- [2] J. Machowski, J. W. Bialek, and J. R. Bumby, *Power System Dynamics: Stability and Control*. Wiley, 2008.
- [3] K. Yamashita, S. Djokic, J. Matevosyan, F. Resende, L. Korunovic, Z. Dong, and J. Milanovic, "Modelling and aggregation of loads in flexible power networks - Scope and status of the work of CIGRE WG C4. 605," in *Power Plants and Power Systems Control*, vol. 8, no. 1, 2012, pp. 405–410.
- [4] J. Slootweg and W. Kling, "Impacts of distributed generation on power system transient stability," *IEEE Power Engineering Society Summer Meeting*, vol. 2, pp. 862–867, 2002.
- [5] M. A. Pai, *Energy Function Analysis For Power System Stability*. Kluwer, 1989.
- [6] F. Dörfler and F. Bullo, "Synchronization and transient stability in power networks and non-uniform Kuramoto oscillators," *SIAM J. Control Optim.*, vol. 50, no. 3, pp. 1616–1642, 2012.
- [7] Y. Susuki, I. Mezić, and T. Hikiyara, "Coherent swing instability of power grids," *Journal of Nonlinear Science*, vol. 21, no. 3, pp. 403–439, Feb. 2011.
- [8] V. Ajarapu and B. Lee, "Bifurcation theory and its application to nonlinear dynamical phenomena in an electrical power system," *IEEE Transactions on Power Systems*, vol. 7, no. 1, pp. 424–431, 1992.
- [9] M. Galaz, R. Ortega, A. S. Bazanella, and A. M. Stankovic, "An energy-shaping approach to the design of excitation control of synchronous generators," *Automatica*, vol. 39, no. 1, pp. 111–119, 2003.
- [10] Y. Hasegawa and Y. Ueda, "Global basin structure of attraction of two degrees of freedom swing equation system," *International Journal of Bifurcation and Chaos*, vol. 9, no. 8, pp. 1549–1569, 1999.
- [11] H.-D. Chiang, *Direct Methods for Stability Analysis of Electric Power Systems: Theoretical Foundation, BCU Methodologies, and Applications*. Wiley, 2011.
- [12] V. R. Sastry, "Validity of neglecting transfer conductances in transient-stability studies," *Proceedings of the Institution of Electrical Engineers*, vol. 120, no. 12, p. 1539, 1973.
- [13] M. J. Laufenberg and M. A. Pai, "A new approach to dynamic security assessment using trajectory sensitivities," in *20th International Conference on Power Industry Computer Applications*, 1997, pp. 272–277.
- [14] A. A. Fouad and S. E. Stanton, "Transient stability of a multi-machine power system Part I: Investigation of system trajectories," *IEEE Transactions on Power Apparatus and Systems*, vol. 100, no. 7, pp. 3408–3416, 1981.
- [15] I. A. Hiskens and M. A. Pai, "Trajectory sensitivity analysis of hybrid systems," *IEEE Transactions on Circuits and Systems I: Fundamental Theory and Applications*, vol. 47, no. 2, pp. 204–220, 2000.
- [16] T. B. Nguyen and M. Pai, "Dynamic security-constrained rescheduling of power systems using trajectory sensitivities," *IEEE Transactions on Power Systems*, vol. 18, no. 2, pp. 848–854, 2003.
- [17] A. Behera, M. Pai, and P. Sauer, "Analytical approaches to determine critical clearing time in multi-machine power systems," in *IEEE Conference on Decision and Control*, Dec 1985, pp. 818–823.
- [18] Y. Xue, T. V. Cutsem, and M. Ribbens-Pavella, "A simple direct method for fast transient stability assessment of large power systems," *IEEE Transactions on Power Systems*, vol. 3, no. 2, pp. 400–412, 1988.
- [19] H. N. Dinh and Y. T. Yoon, "Two novel methods for real time determining critical clearing time: SIME-B and CCS-B based on clustering identification," in *Third International Conference on Intelligent Systems, Modelling and Simulation (ISMS)*, Feb 2012, pp. 510–515.
- [20] A. Grilo, A. Mota, L. Mota, and W. Freitas, "An analytical method for analysis of large-disturbance stability of induction generators," *IEEE Transactions on Power Systems*, vol. 22, no. 4, pp. 1861–1869, Nov 2007.
- [21] J. Tong, H.-D. Chiang, and T. Conneen, "A sensitivity-based BCU method for fast derivation of stability limits in electric power systems," *IEEE Transactions on Power Systems*, vol. 8, no. 4, pp. 1418–1428, Nov 1993.
- [22] H.-D. Chiang and C.-C. Chu, "Theoretical foundation of the BCU method for direct stability analysis of network-reduction power system models with small transfer conductances," *IEEE Transactions on Circuits and Systems I: Fundamental Theory and Applications*, vol. 42, no. 5, pp. 252–265, 1995.
- [23] L. Wang, M. Klein, S. Yirga, and P. Kundur, "Dynamic reduction of large power systems for stability studies," *IEEE Transactions on Power Systems*, vol. 12, no. 2, pp. 889–895, 1997.
- [24] R. Singh, M. Elizondo, and S. Lu, "A review of dynamic generator reduction methods for transient stability studies," in *IEEE Power and Energy Society General Meeting*, 2011.
- [25] P. M. Anderson and A. A. Fouad, *Power System Control and Stability*, 2nd ed. IEEE Press, 2002.
- [26] F. Dörfler and F. Bullo, "Kron reduction of graphs with applications to electrical networks," *IEEE Transactions on Circuits and Systems I: Regular Papers*, vol. 60, no. 1, pp. 150–163, Jan. 2013.
- [27] A. Gajduk, M. Todorovski, and L. Kocarev, "Stability of power grids: An overview," *The European Physical Journal Special Topics*, vol. 223, no. 12, pp. 2387–2409, Jun. 2014.
- [28] M. Ribbens-Pavella and F. Evans, "Direct methods for studying dynamics of large-scale electric power systems: A survey," *Automatica*, vol. 21, no. 1, pp. 1–21, Jan. 1985.
- [29] T. Athay, R. Podmore, and S. Virmani, "A practical method for the direct analysis of transient stability," *IEEE Transactions on Power Apparatus and Systems*, vol. 98, no. 2, pp. 573–584, 1979.
- [30] F. M. Hughes, O. Anaya-Lara, N. Jenkins, and G. Strbac, "A power system stabilizer for DFIG-based wind generation," *IEEE Transactions on Power Systems*, vol. 21, no. 2, pp. 763–772, May 2006.
- [31] A. Ulbig, T. S. Borsche, and G. Andersson, "Impact of low rotational inertia on power system stability and operation," in *Proceedings of the 19th IFAC World Congress*, 2014.
- [32] K. Johnstone, R. M. Tumilty, K. R. W. Bell, and C. D. Booth, "Transient stability assessment of the GB transmission system with high penetrations of wind power," *13th International Workshop on Large-scale Integration of Wind Power into Power Systems as well as on Transmission Networks for Offshore Wind Power Plants*, 2014.
- [33] A. Llamas, J. De La Ree Lopez, L. Mili, A. G. Phadke, and J. S. Thorp, "Clarifications of the BCU method for transient stability analysis," *IEEE Transactions on Power Systems*, vol. 10, no. 1, pp. 210–219, 1995.
- [34] M. Anghel, F. Milano, and A. Papachristodoulou, "Algorithmic construction of Lyapunov functions for power system stability analysis," *IEEE Transactions on Circuits and Systems I: Regular Papers*, vol. 60, no. 9, pp. 2533–2546, 2013.
- [35] Y. Guo, D. J. Hill, and Y. Wang, "Nonlinear decentralized control of large-scale power systems," *Automatica*, vol. 36, no. 9, pp. 1275 – 1289, 2000.
- [36] C. Chia-Chi, "Towards a theory of multi-swing transient instability problems in electric power systems," *IEICE Transactions on Fundamentals of Electronics, Communications and Computer Sciences*, vol. E88-A, no. 10, pp. 2692–2695, 2005.
- [37] C. W. Liu and J. S. Thorp, "A novel method to compute the closest unstable equilibrium point for transient stability region estimate in power systems," *IEEE Transactions on Circuits and Systems I: Fundamental Theory and Applications*, vol. 44, no. 7, pp. 630–635, 1997.
- [38] L. Chen, Y. Min, F. Xu, and K.-P. Wang, "A continuation-based method to compute the relevant unstable equilibrium points for power system transient stability analysis," *IEEE Transactions on Power Systems*, vol. 24, no. 1, pp. 165–172, Feb 2009.
- [39] R. Seydel, *Practical bifurcation and stability analysis*. Springer Science & Business Media, 2009, vol. 5.
- [40] J. Lee and H.-D. Chiang, "A singular fixed-point homotopy method to locate the closest unstable equilibrium point for transient stability region estimate," *IEEE Transactions on Circuits and Systems II: Express Briefs*, vol. 51, no. 4, pp. 185–189, April 2004.
- [41] T. Wang and H.-D. Chiang, "On the global convergence of a class of homotopy methods for nonlinear circuits and systems," *IEEE Transactions on Circuits and Systems II: Express Briefs*, vol. 61, no. 11, pp. 900–904, Nov 2014.
- [42] S. Strogatz, *Nonlinear Dynamics and Chaos: With Applications to Physics, Biology, Chemistry and Engineering*. Westview Press, 2001.
- [43] B. Delfino, G. Denegri, M. Invernizzi, and P. Pinceti, "Estimating first swing stability of synchronous machines as affected by saturation

controls,” *IEEE Transactions on Energy Conversion*, vol. 3, no. 3, pp. 636–646, 1988.

- [44] H.-D. Chiang, “A theory-based controlling UEP method for direct analysis of power system transient stability,” in *IEEE International Symposium on Circuits and Systems*, vol. 3, May 1989, pp. 1980–1983.
- [45] H.-D. Chiang, F. F. Wu, and P. P. Varaiya, “A BCU method for direct analysis of power system transient stability,” *IEEE Transactions on Power Systems*, vol. 9, no. 3, pp. 1194–1208, 1994.
- [46] C. J. Tavora and O. J. M. Smith, “Equilibrium analysis of power systems,” *Transactions on Power Apparatus and Systems*, vol. 91, no. 3, pp. 1131–1137, 1972.
- [47] J. Lee, “Dynamic gradient approaches to compute the closest unstable equilibrium point for stability region estimate and their computational limitations,” *IEEE Transactions on Automatic Control*, vol. 48, no. 2, pp. 321–324, Feb. 2003.
- [48] M. O’Brien and G. Ledwich, “Static reactive-power compensator controls for improved system stability,” in *IEE Proceedings C (Generation, Transmission and Distribution)*, vol. 134, no. 1. IET, 1987, pp. 38–42.
- [49] K. Bell and A. Hiorns, “Management of increased power flow on the NGC transmission system,” in *CIGRE London Symposium (1999-6)*, 1999.
- [50] M. Noroozian, M. Ghandhari, G. Andersson, J. Gronquist, and I. Hiskens, “A robust control strategy for shunt and series reactive compensators to damp electromechanical oscillations,” *IEEE Power Engineering Review*, vol. 21, no. 7, pp. 72–72, July 2001.
- [51] G. M. Huang, “Global bifurcation points and the transversality condition,” in *American Control Conference*, June 1991, pp. 550–551.
- [52] C.-W. Tan, M. Varghese, P. Varaiya, and F. F. Wu, “Bifurcation, chaos, and voltage collapse in power systems,” *Proceedings of the IEEE*, vol. 83, no. 11, pp. 1484–1496, 1995.
- [53] H. Urdal, R. Ierna, J. Zhu, C. Ivanov, A. Dahresobh, and D. Rostom, “System strength considerations in a converter dominated power system,” *IET Renewable Power Generation*, 2014.
- [54] T. B. Nguyen, M. A. Pai, and E. Muljadi, “Impact of wind power plants on voltage and transient stability of power systems,” in *IEEE Energy2030*, 2008.
- [55] D. Gautam, V. Vittal, and T. Harbour, “Impact of increased penetration of DFIG-based wind turbine generators on transient and small signal stability of power systems,” *IEEE Transactions on Power Systems*, vol. 24, no. 3, pp. 1426–1434, 2009.
- [56] P. Tielens and D. V. Hertem, “Grid inertia and frequency control in power systems with high penetration of renewables,” in *Young Researchers Symposium in Electrical Power Engineering*, 2012.

Alan R. Champneys is Professor of Applied Non-linear Mathematics in the Department of Engineering Mathematics at the University of Bristol. Following a DPhil from the University of Oxford in Applied Mathematics and a post-doctoral position at Bath, he has been on the Faculty at Bristol since 1993. His research interests span nonlinear science, including contributions in mathematics, computation, optics, mechanics and biology. He is especially known for his work on bifurcations, piecewise-smooth dynamical systems and localized pattern formation. He has served as chair of the SIAM Activity Group on Dynamical Systems (2010–2011) and as member of the Strategic Advisory Team of the UK Engineering and Physical Sciences Research Council (2001–4, 2014–). He is an editorial board member of *Journal of Nonlinear Science* and editor of the *IMA Journal of Applied Mathematics* and serves on the Scientific Board of the Smith Institute of Industrial Mathematics. He has published over 120 journal papers and has an h-index of 40 (Google Scholar) with over 8000 citations of his work.

Lewis G. W. Roberts received the MPhys degree in physics from the University of Oxford, United Kingdom, in 2010. From 2010 to 2011, he was with Christ’s College, Christchurch, New Zealand working as a tutor of Mathematics. Following this, he joined the Centre for Complexity Sciences at the University of Bristol, United Kingdom, receiving the MRes degree in complexity sciences in 2013 (with Distinction) and has continued on to study for the PhD degree at this institution. His research interests include the study of synchronisation, stability, power system dynamics, nonlinear dynamics and bifurcation theory.

Keith R. W. Bell is the ScottishPower Professor of Smart Grids at the University of Strathclyde. He joined the University in 2005 having previously gained his PhD at the University of Bath and worked as an electrical engineering researcher in Manchester and Naples, and as a system development engineer in the electricity supply industry in Britain. He is a co-Director of the multi-disciplinary UK Energy Research Centre (UKERC), an invited expert member of CIGRE Study Committee C1 on System Development and Economics and a member of the

Council of the IET Power Academy, an initiative to promote electric power engineering as a graduate career in the UK. He is a Chartered Engineer and his research interests include power system development and operation and grid integration of renewables.

Mario di Bernardo (SMIEEE 06, FIEEE 2012) is currently Full Professor of Automatic Control at the University of Naples Federico II, Italy. He is also Professor of Nonlinear Systems and Control at the University of Bristol, U.K. On 28th February 2007 he was bestowed the title of "Cavaliere" of the Order of Merit of the Italian Republic for scientific merits from the President of Italy. In January 2012 he was elevated to the grade of Fellow of the IEEE for his contributions to the analysis, control and applications of nonlinear systems and complex

networks. In 2009, he was elected President of the Italian Society for Chaos and Complexity for the term 2010-2013. He was re-elected in 2010 for the term 2014-2017. In 2006 and again in 2009 he was elected to the Board of Governors of the IEEE Circuits and Systems Society. From 2011 to 2014 he was Vice President for Financial Activities of the IEEE Circuits and Systems Society. In 2014 he was appointed to the Board of Governors of the IEEE Control Systems Society. His research interests include the analysis, synchronization and control of complex networked systems; the analysis and control of hybrid and piecewise-smooth dynamical systems; nonlinear dynamics, nonlinear control theory and applications to engineering and synthetic biology. He authored or co-authored more than 220 international scientific publications including more than 110 papers in scientific journals, over 100 contributions to refereed conference proceedings, a unique research monograph on the dynamics and bifurcations of piecewise-smooth systems published by Springer-Verlag and two edited books. His h-index is 34 and his publications received over 4500 citations by other authors. He serves on the Editorial Board of several international scientific journals and conferences. From 1st January 2014 he is Deputy Editor-in-Chief of the IEEE Transactions on Circuits and Systems: Regular Papers. He is also Associate Editor of the IEEE Transactions on Control of Network and Nonlinear Analysis: Hybrid Systems, the Conference Editorial Board of the IEEE Control System Society and the European Control Association (EUCA). He was Associate Editor of the IEEE Transactions on Circuits and Systems I: Regular Papers from 1999 to 2002 and again from 2008 to 2010, and the IEEE Transactions on Circuits and Systems II: Brief papers from 2003 till 2008. He is regularly invited as Plenary Speakers in Italy and abroad. He has been organizer and co-organizer of several scientific initiatives and events including international events at Urbino (2011 & 2013), Paris (2010), Bristol (2009), Napoli (2006), Capri (2006), Bristol (2004), Milano (2004). He received funding from several institutions including the EU, the Italian Ministry of University and Research, the UK Research Councils and Industry.