



Ahamat, M. A., & Tierney, M. J. (2016). Calorimetric Assessment of Rates of Desorption. *Heat Transfer Engineering*, 37(7-8), 713-719. <https://doi.org/10.1080/01457632.2015.1067091>

Peer reviewed version

Link to published version (if available):  
[10.1080/01457632.2015.1067091](https://doi.org/10.1080/01457632.2015.1067091)

[Link to publication record on the Bristol Research Portal](#)  
PDF-document

This is an Accepted Manuscript of an article published by Taylor & Francis in *Heat Transfer Engineering* on 16/11/2015, available online: <http://www.tandfonline.com/doi/pdf/10.1080/01457632.2015.1067091>.

## University of Bristol – Bristol Research Portal

### General rights

This document is made available in accordance with publisher policies. Please cite only the published version using the reference above. Full terms of use are available: <http://www.bristol.ac.uk/red/research-policy/pure/user-guides/brp-terms/>

## CALORIMERIC ASSESSMENT OF RATES OF DESORPTION

Mohamad A AHAMAT<sup>1</sup>, Michael J. TIERNEY<sup>2\*</sup>,

<sup>1</sup>HVAC&R Section, Universiti Kuala Lumpur, Malaysia France Institute, Section 12, Jalan Teras

Jernang, 43650 Bandar Baru Bangi, Selangor, Malaysia

<sup>2</sup>Department of Mechanical Engineering, University of Bristol, Bristol BS8 1TR, UK

\*Author to whom correspondence should be addressed

E-mail: [mike.tierney@bristol.ac.uk](mailto:mike.tierney@bristol.ac.uk),

Tel +44 (0)177 3315903

### ABSTRACT

This paper concerns the further testing of a new double calorimeter. We earlier reported initial development of the calorimeter and thereafter inferred rates coefficients for adsorption of moisture under a “large pressure jump”. (The test materials were Silica Gel type A and water.) The current paper presents a further check on the calorimeter by demonstrating that measured desorption and adsorption rates were compatible.

A disappointing aspect was an unintended near step change in condenser pressure at the start of the experiment. The condenser design was deficient and better drainage is needed in future to maintain vapour in immediate contact with cold surfaces. Notwithstanding the lower-than-intended pressure driving force, the heat addition to the silica gel was measurable, following an exponential pattern

against time with regression coefficient better than  $r^2 = 99\%$ . The rate coefficients that fitted each dataset were broadly in line with coefficients reported for adsorption (within the limits of experimental error).

**Keywords:** Desorption, calorimetry, rate constant, large pressure jump, thermo-electric module

The paper was originally submitted as paper#036 at IMPRES2013, and invited for a special issue of Heat Transfer Engineering

## NOMENCLATURE

|           |   |  |
|-----------|---|--|
| $c_{pr}$  | specific heat capacity of refrigerant vapour                    | $[\text{J kg}^{-1} \text{K}^{-1}]$       |
| $h_{ads}$ | specific heat of adsorption                                     | $[\text{J kg}^{-1}]$                     |
| $K$       | rate constant   | $[\text{s}^{-1}]$                        |
| $m_x$     | mass of adsorbent   | kg                                       |
| $p$       | vapour pressure   | Pa, mbar                                 |
| $p_{sat}$ | saturation pressure   | Pa, mbar                                 |
| $Q_a$     | heat accepted/ rejected from aluminium plate                    | J  |
| $R$       | Specific gas constant   | $[\text{J kg}^{-1} \text{K}^{-1}]$       |
| $t$       | time  | s  |
| $T_b$     | temperature measured at aluminium plate<br>(close to adsorbent) | K  |
| $T_v$     | temperature of refrigerant vapour                               |  |
| $R$       | specific gas constant   | $[\text{J kg}^{-1} \text{K}^{-1}]$       |
| $X$       | adsorbent loading   | $[\text{kg (adsorbate)/kg (adsorbent)}]$ |
| $X^*$     | adsorption capacity (loading under equilibrium)                 | $[\text{kg (adsorbate)/kg (adsorbent)}]$ |
| $A_0$     | Pre-exponential constant  | (-)                                      |

## INTRODUCTION

This paper concerns the development of a double calorimeter that tracks the processes of adsorption or desorption. The measured rates of the adsorption of moisture onto silica gel beads were published previously [1]; in the current paper we have further tested the instrument by ascertaining whether or not measured rates of desorption are identical. Results were not of the quality wished for (in terms of the control of boundary conditions). Nonetheless, they usefully confirm previous adsorption data, and point to future improvements in the experiment.

Adsorbents are employed in Adsorption Heat Pumps (AHPs); devices that amplify heat or convert waste heat to refrigeration. A number of adsorption cycles of varying complexity are described, for example Oliveria et al [2]. Ng [3] argues that the adsorption cycle has several advantages over the liquid, absorption cycle including minimal number of moving parts, cooling pumps that are easily purchased, and that the absence of corrosive materials allows the use of low-cost carbon steel. Within AHPs, the important aspects of the adsorbent are its adsorption capacity, the sensitivity of this capacity to temperature, and the rate of refrigerant uptake.

One of the most widely used methods of evaluating adsorption kinetics and equilibria is the magnetic levitation scale (mainly the Rubothermscale [4,5]) and the "large temperature jump" (LTJ)[6]. The Rubotherm device is expensive, and demands extensive fitting out for corrosive or high pressure refrigerants. The sample pan is held within a constant temperature environment, but one cannot cycle the pan temperature in a controlled manner. The "large temperature jump"(LTJ) [6] operates by resting a single grain of adsorbant on a plate, stepping the plate temperature in the same way as the isobaric processes within a chiller cycle, and monitoring the mass adsorbed (equal to the calculated mass lost from a reservoir of adsorbate vapour). The LTJ produces excellent data for single grains, but should it be required to test several dozen grams of adsorbent, quite possibly adhered to fins or mixed with a

heat transfer enhancement, then the necessary reservoir could be huge. Our calorimeter has worked with samples weighing between 5 g and 15 g [1] and also adsorbent sandwiched between 40-mm long fins [7]. The method is intended ultimately for relatively complex systems, for instance when the adsorbent is coated onto large fins so that a large sample must be dealt with [8]. The temperature control is to within 0.1 K of set point, and to date the temperatures of inert, aluminium samples can be cycled in the form of triangular wave or sine wave with simultaneous measurement of heat flow [9]. The calorimeter [1] simultaneously detected heats of phase change in both evaporation and adsorption. To check the method adsorption capacities were inferred from measured heat rejection and confirmed to be within 10% of independently published gravimetric measurements [10]. Because the equipment is at an earlier stage of development, it has to date been more straightforward to run tests with the adsorbent held nominally isothermal and to impose “large pressure jumps” [11].

This paper summarises the calorimeter, gives new data for rates of desorption and compares these against previously reported adsorption rates. Problems in controlling pressures are discussed with a view to future developments in the equipment.

## **METHODS AND ANALYSIS**

The calorimeter, its calibration and its operating procedure are described fully in [1][9]. In summary, it comprised glass adsorber and condenser sections, separated by a valve (Fig. 1). Each section was bounded by a 50-mm-diameter horizontal aluminium plate fitted with thermo-electric modules (TEMs, item 5 in part b). The plate temperatures were monitored with K-type thermocouples, either lodged inside 0.5-mm-diameter holes drilled into the upper plate to give a reading  $T_b$ , or resting on the surface of the lower plate. The TEMs behaved as heaters or coolers according to the direction of electrical current. The calculated heat flows comprised three components: the Peltier effect at the TEM

faces, ohmic heating within the TEM, and thermal conduction between the TEM faces. Calibration errors of the TEM were assessed as 10% [9], comparable to the discrepancy between calorimetrically inferred adsorption capacities and Wang et al's gravimetric measurements [1, 10].

The adsorbent was a 5-gram sample of type A silica gel beads, 3-mm in diameter and adhered to an aluminium plate with silicone sealant.

In preparation for adsorption tests the adsorbent was isolated by closing the connecting valve (item 3 in Fig. 1). Heating and vacuum were applied after which the adsorbent and water were brought to their set point temperatures [1]. The connecting valve was then opened.

The adsorption capacity (Fig. 2) was estimated as follows. If changes to the sensible heat of the adsorbent are neglected, then,

$$Q(t) \approx m_x (X(t) - X(0))(h_{ads} - c_{p,r} (T_b - T_v)) \quad [1]$$

where  $c_{p,r}$  is the heat capacity of vapour at constant pressure,  $h_{ads}$  is the average isosteric enthalpy of adsorption, inferred from Antoine plots of the adsorption isotherm slope,  $m_x$  is the mass of adsorbent (silica gel), and  $Q(t)$  is the net heat rejection (in joules) at time  $t$  after the start of the experiment. Also  $T_b$  is the measured, near constant temperature of the aluminium plate and  $T_v$  is the temperature of vapour approaching the sample, taken as the evaporator temperature for adsorption. For desorption one assumes  $T_v = T_b$ . Term  $X(t)$  is instantaneous loading and for adsorption  $X(0) \rightarrow 0$ . At equilibrium ( $t \rightarrow \infty$ ) Equation 1 was manipulated to give adsorption capacity  $X^*$ . Heat transfer and loading are approximately in proportion,  $Q(t) \propto X(t)$ .

In reference [1], the adsorption capacity was fitted to Henry's law (Fig. 2)

$$X^* = A_o (\exp [h_{ads} / RT_b]) p \quad (2)$$

where  $X^*$  is the adsorption capacity,  $h_{ads} = 2495 \text{ kJ kg}^{-1}$  is the heat of adsorption,  $A_o = 1.92 \times 10^{-12} \text{ Pa}^{-1}$  is a pre-exponential constant. (A Toth equation [10] applies when the adsorption capacity exceeds 30%.)

Desorption tests were designed to expose each sample to a step reduction in moisture pressure. To set initial conditions, two hours were allowed for the water (lower section), water vapour and silica gel (upper section) to achieve equilibrium. The connecting valve (item 3, Fig 1a) was open, and water in the lower section was held at roughly 303 K. Then, the connecting valve was closed, the desorber temperature was maintained and the refrigerant was cooled to typically 281 K (at which the measured vapour pressure was 1100 Pa). This condition was held for 30 minutes, during which any stray heat flow to-or-from the surroundings was estimated. The test proper was started by opening the connecting valve; pressures and heat flows were recorded against time.

Table 1 summarises the expected errors of measurement in temperature, pressure and heat transfer.

### 3. RESULTS

This section reports the thermal behaviour of the calorimeter and compares rate coefficients for adsorption with rate coefficients for desorption.

The pressure inside the condenser section was not controlled as well as intended; the adsorption tests had been more promising (Fig. 3). Typically, the vapour pressure inside the condenser section increased from 1100 Pa to 1500 Pa after the connecting valve was opened (at time,  $t > 0 \text{ s}$ ), before gradually falling to 1400 Pa. This suggests that the water layer exerted its thermal resistance so that water surface temperature exceeded that measured at the aluminium plate.



Figure 4 serves to illustrate the correction of unwanted heat losses. On part a, attention is drawn to the portion of the graph at  $t < 0$ , before the start of the test proper and where ideally the indicated flow of heat would be zero. Under these conditions directly measured heat rejection corresponded to unwanted losses and instrument offset, and, on extrapolation beyond  $t > 0$ , was subtracted from raw data. The condenser section (part (a) in Figure 1) required a relatively large adjustment, this is included to illustrate the method of correction but the corrected data were omitted from further detailed analysis. (Condenser side-walls had to be hotter than the dew point temperature, introducing the stray heat gains). Less correction was needed for the desorber section, wherein side-wall and sample temperatures were better matched.

It has been found that plots of corrected heat rejection can be fitted statistically to exponential recovery or decay [1,7],

$$Q(t) = Q(\infty) [1 - \exp(-K(T_b)t)] \quad (3)$$

Where  $Q$  is the net heat addition (in joules) and the rate constant  $K$  is approximately proportional to that used in the linear driving force model of heat transfer (see discussion section).

Exponential functions were fitted to experimental data (Fig 6) with  $r^2 > 99\%$  (Table 2). The rate coefficient,  $K$ , for desorption increased as the nominal sample temperature  $T_b$  increased (Fig.6), and lay within the range previously found for adsorption.

To check the hypothesis that the layer of condensate formed an appreciable thermal resistance the temperature of the adsorbent was maintained at 303 K while the temperature of the refrigerant (water) was varied sinusoidally. The indicated temperature  $T_b$  followed its set point to within 0.2 K. Figure 7 shows the measured and saturation pressures ( $p_{sat}(T_b)$ ). The saturation pressure and

measured pressure tended to good agreement in the boiling phase (increasing pressure) but diverged by as much as 600 Pa in the condensing phase. This confirms the ineffectiveness of the condenser, as observed in the desorption tests.

## DISCUSSION

A previous kinetic test was reversed to study desorption rather, than adsorption. The results appear promising –the sets of rate coefficients were within 10% of each other.

One problematic aspect was the evident pressure difference between desorber and condenser (initially about 1650-1500 = 150 Pa, Fig. 3). This far exceeded any calculated frictional loss; some months after these experiments the valve was inspected and damage to the diaphragm was evident. This may have been caused solely by the use of methanol at that time, or earlier degradation may have contributed to the observed pressure loss.

More worrying is the step change in condenser pressure above its expected, initial value (Fig. 3). From tabulated saturation pressures, the surge corresponded to the water surface being 3.5 K hotter than the measured aluminium plate, at  $T_b$ , and hence a temperature gradient through the water. Even were the water to form a quiescent layer, by Fourier's law such a gradient would conduct ~0.8 watts (through a 5-mm-deep layer), of the same order as heat rejected by the condenser. We have been unable to control evaporator temperature by putting thermocouples in the bulk liquid, owing to rapid temperature fluctuations. A further measurement nearer to the water surface should be considered in future, but also an experiment is needed in which the condenser can drain freely. An increased condenser surface area would also be helpful. No pressure surges were evident when adsorption was tested, and the lower section of the rig acted as an evaporator. The limitation of the "condenser" was confirmed following the sinusoidal variation in set-point temperature  $T_b$  (Fig 7). Measured pressures

repeatedly tended to match the calculated saturation during evaporation, but lagged during condensation.

Notwithstanding issues with pressure control, the desorption trends matched the exponential form of the adsorption trends. Equation 1 indicates  $Q \propto X^*$  and then differentiating Equation 3 gives Gluekauf's linear driving force model [12]

$$\frac{dX}{dt} = K(T_b)(X^*(p, T_b) - X) \quad [4]$$

Note, however, that the temperature gradients within the bead, and thermal resistance from bead to plate, render the coupled conduction and diffusion complex. Thus, here Gluekauf's straightforward model does not yield a reliable intra-bead diffusivity from the rate coefficient,  $K(T_b)$ . With regard to LTJ in particular, Aristov [13] remarks on the tendency of uptake ( $X$ ) to follow the linear kinetics, notwithstanding sophisticated coupled phenomena.

The difference in rate coefficients – adsorption versus desorption – is 10% at most if lines of best fit are considered, versus scatter of  $\pm 20\%$  in the adsorption study. Greater accuracy and repeatability could come through using larger sample masses and hence larger equipment (larger TEMs have since become commercially available). Also, the binder may well have progressively blocked mesopores to the detriment of both the magnitude and the consistency of rate coefficient  $K(T_b)$ . Tests without binder are in progress.

The rate coefficient might be less for desorption than for adsorption, owing to temperature gradients inside the beads. The interior bead temperature would exceed  $T_b$  during adsorption and be less than  $T_b$  during desorption. The local, centre-of-bead driving force would thus be reduced for both processes. (For desorption intra-bead cooling reduces local  $X - X^*(T)$ , for adsorption intra-bead heating reduces  $X^*(T) - X$ ). On the other hand one would expect temperature peaks to increase rate coefficients for adsorption but decrease them for desorption.

Our ultimate intention is to use this method to simulate complete cycles of an adsorption heat pump. One difficulty is the finite heat capacity of the aluminium plate separating sample from TEM, which if too large prevents sufficiently rapid temperature change. Some experiments [7] have now been completed with the TEM inside the adsorption/ desorption vessel, and in direct contact with the sample.

## **CONCLUSIONS**

A calorimeter was previously employed to study rates of moisture adsorption. The function has been reversed, to study desorption. It is encouraging that for both types of experiment the sorbent heat rejection or addition follows an exponential function, and that within current experimental error the measured rates of mass transfer are similar. However, the moisture pressure requires more effective and precise control. This could be achieved by building a condenser that drains freely.

## **ACKNOWLEDGEMENTS**

The authors thank Malaysian government through MARA and Universiti Kuala Lumpur for funds provided for Dr Ahamat's Ph.D. study, and also the Leverhulme Trust UK under grant number F00182CD for their assistance with continued work.

## REFERENCES

- 1 Ahamat, M. A. and M. J. Tierney. "Calorimetric assessment of adsorbents bonded to metal surfaces: application to type A silica gel bonded to aluminium." *Applied Thermal Engineering* 40 (2012): 258-266
- 2 Oliveira, R. G., Silveira Jr, V., & Wang, R. Z. (2010). Solar-Powered Adsorption Icemaker With Double-Stage Mass Recovery Cycle. *Heat Transfer Engineering*, 31(11), 941-949
- 3 Ng, K. C. (2003). Recent developments in heat-driven silica gel-water adsorption chillers. *Heat Transfer Engineering*, 24(3), 1-3
- 4 Dreisbach F. and Loesch H. W. "Magnetic suspension balance for simultaneous measurement of a sample and the density of the measuring fluid", *J. Thermal Analysis and Calorimetry* 62 (2006): 515-521
- 5 Wang, L.W, Tamainot-Telto, Z., Thorpe R., Critoph, R.E., Metcalf, S., Wang, R. Z "Study of thermal conductivity, permeability, and adsorption performance of consolidated composite activated carbon adsorbent for refrigeration.", *Renewable Energy* 36 (2011): 2062-2066
- 6 Aristov, Yu I., B. Dawoud, I. S. Glaznev, and A. Elyas. "A new methodology of studying the dynamics of water sorption/desorption under real operating conditions of adsorption heat pumps: Experiment." *International Journal of Heat and Mass Transfer* 51, no. 19 (2008): 4966-4972
- 7 Ketteringham, L., Martin, A., Richards, B., Tierney, M., Turtle, B "Characterising a reactor concept for adsorption chillers: calorimetric tests", Paper no. 810, Heat Powered Cycles Conference, Alkmaar, Holland, September 2012
- 8 Waszkiewicz, S., Jenkins, S., Saidani-Scott, H., & Tierney, M. (2003). Analysis of a finned heat exchanger working in an adsorption refrigeration system using zeolite and methanol. *Heat transfer engineering*, 24(6), 71-78
- 9 Ahamat, M. A., and M. J. Tierney. "Timewise temperature control with heat metering using a thermoelectric module." *Applied Thermal Engineering* 31, (2011): 1421-1426
- 10 Wang, X., Zimmermann, W., Ng, K.C., Chakraborty, A. and Keller, J.U." Investigation on the isotherm of silica gel + water systems TG and volumetric methods". *Journal of Thermal Analysis and Calorimetry* 76, (2004): 659-669
- 11 Okunev, B. N., Gromov, A. P., Heifets, L. I., & Aristov, Y. I. (2008). Dynamics of water sorption on a single adsorbent grain caused by a large pressure jump: Modeling of coupled heat and mass transfer. *International Journal of Heat and Mass Transfer*, 51(25), 5872-5876
- 12 E. Gluekauf Theory of chromatography, part 10. Formula for diffusion into spheres and their application to chromatography *Trans. Faraday Soc.*, 51 (1955): 1540-1551
- 13 Aristov, Y. I. (2013). Adsorption Dynamics in Adsorptive Heat Transformers: Review of New Trends. *Heat Transfer Engineering*, (just-accepted).

## List of Tables and Figures

Figure 1 The schematic of calorimetric apparatus (a) general view with (1) evaporator section (2) adsorber section (3) connecting valve and (4) thermocouple locations (black dots). The total height of the assembly is about 350 mm. (b) Detailed view of adsorber section with (1) thermocouple location (2) silica gel sample (3) nylon screws (4) aluminium end plate (5) thermoelectric module (6) heat sink and fan.

Figure 2 Inferred adsorption capacities (open symbols and solid lines) compared with gravimetrically inferred data from Wang et al [10] (full symbols and dashed lines). The authors have applied to Elsevier for permission to publish this Figure

Figure 3 Pressures inside the two sections of the calorimetric apparatus. The connecting valve was opened at time = 0 s. (a) conditions for adsorption, evaporator temperature = 303K and adsorbent temperature = 306 K (b) conditions for desorption, with adsorbent temperature = 303K and condenser temperature = 283 K. The authors have applied to Elsevier for permission to publish part (a)

Figure 4 Measured heat flows and correction for losses (a) in condenser, showing correction for losses (b) in desorber


Figure 5 Heat flows during (a) adsorption (b) desorption. Nominal sample temperatures are written above trend lines and other conditions on Table 2. Solid lines represent data and dashed lines data-fitting to exponential decay. Permission has been sought from Elsevier for publication of part (a)

Fig. 6 Comparison of rate coefficient for desorption and adsorption (reported in [1])


Figure 7 Response to a sinusoidal change in set point temperature  $T_b$  (a) over several cycles (b) detailed view of one cycle.  $T_b$  varied sinusoidally between 281 K and 298 K. Term  $p_{sat}$  is the saturation temperature calculated from  $T_b$

Table 1 Measurement uncertainties and error analysis

Table 2 Conditions for the desorption test presented in Figure 5b (Condenser temperature = 285 K)



(a)



(b)

Figure 1 The schematic of calorimetric apparatus (a) general view with (1) evaporator section (2) adsorber section (3) connecting valve and (4) thermocouple locations (black dots). The total height of the assembly is about 350 mm. (b) detailed view of adsorber section with (1) thermocouple location (2) silica gel sample (3) nylon screws (4) aluminium end plate (5) thermoelectric module (6) heat sink and fan.






Figure 2 Inferred adsorption capacities (open symbols and solid lines) compared with gravimetrically inferred data from Wang et al [10] (full symbols and dashed lines) [1]. *Reprinted from Applied Thermal Engineering, Vol. 40, M. A. Ahamat and M. J. Tierney, Calorimetric assessment of adsorbents bonded to metal surfaces, Copyright 2012, with permission from Elsevier.*






(a)




(b)

Figure 3 Pressures inside the two sections of the calorimetric apparatus. The connecting valve was opened at time = 0 s. (a) conditions for adsorption, evaporator temperature = 303K and adsorbent temperature = 306 K [1] (b) conditions for desorption, with adsorbent temperature = 303K and condenser temperature = 283 K. Part (a) reprinted from *Applied Thermal Engineering*, Vol. 40, M. A. Ahamat and M. J. Tierney, *Calorimetric assessment of adsorbents bonded to metal surfaces*, Copyright 2012, with permission from Elsevier.




(a)




(b)

Figure 4 Measured heat flows and correction for losses (a) in condenser, showing correction for losses (b) in desorber



(a)



(b)

Figure 5 Heat flows during (a) adsorption [1] (b) desorption. Nominal sample temperatures are written above trend lines and other conditions on Table 2. Solid lines represent data and dashed lines data-fitting to exponential decay. Part (a) reprinted from *Applied Thermal Engineering*, Vol. 40, M. A. Ahamat and M. J. Tierney, *Calorimetric assessment of adsorbents bonded to metal surfaces*, Copyright 2012, with permission from Elsevier.






Fig. 6 Comparison of rate coefficient for desorption and adsorption (reported in [1])



(a)



(b)

Figure 7 Response to a sinusoidal change in set point temperature  $T_b$  (a) over several cycles (b) detailed view of one cycle.  $T_b$  varied sinusoidally between 281 K and 298 K. Term  $p_{sat}$  is the saturation temperature calculated from  $T_b$

**Table 1**  
**Measurement uncertainties and error analysis**

| Item no                      | Source of uncertainty                                    | Justification  | Error              |
|------------------------------|--|--|--------------------|
| <i>Heat flow measurement</i> |  |  |                    |
| 1                            | Measured heat flow                                       | Assessed in [9]  | 10.0%              |
| 2                            | Correction for extraneous heat loss                      | Prior to experiment, variation from constant heat flow is $\pm 40$ J. Produces uncertainty in correction for stray losses. | 1.6%               |
| 3                            | Refrigerant temperature in sample section is an estimate | In Equation [1], change estimate of $T_e$ from evaporator to vessel wall temperature                                       | 3.8%               |
|                              | <b>Total uncertainty</b>                                 | $\sqrt{10^2 + 1.6^2 + 3.8^2}$  | 10.8%              |
| Vapour pressure measurement  |  |  |                    |
| 4                            | Gauge error  | Manufacture claims repeatability of 0.2% f.s.d.  | 200 Pa             |
| 5                            | Temperature drift  | Sensitivity of 0.05% full scale per Kelvin, 2°C uncertainty in gauge temperature   | 100 Pa             |
| 6                            | Data logger  | Resolution of 12 bit device  | 20 Pa              |
|                              | <b>Total uncertainty</b>                                 | $\max(50, \sqrt{200^2 + 100^2})$   | 220 Pa,<br>2.2mbar |
| Temperature measurement      |  |  |                    |
| 7                            | Sensor error   | Thermocouple random error  | 0.5 K              |

**Table 2**  
**Conditions for the desorption test presented in Figure 5b (Condenser temperature = 285 K)**

| <b>Desorber Temperature, K</b> | <b>Initial Pressure, Pa<br/>(Isolated desorber at<br/>equilibrium)</b> | <b>Final pressure, Pa<br/>(End of experiment)</b> |
|--------------------------------|--|---|
| 303                            | 2400   | 1400  |
| 308                            | 3500   | 1400  |
| 313                            | 3500   | 1400  |
| 323                            | 3500   | 1400  |
| 333                            | 3500   | 1400  |

## Author Biographies



**Mohamad AsmidzamAhamat** obtained his Master of Engineering in Mechanical Engineering and Doctor of Philosophy from the University of Bristol, United Kingdom. He is an academic staff at the Heating, Ventilating, Air Conditioning and Refrigerating Section, Universiti Kuala Lumpur, Malaysia France Institute in Malaysia. His research interest includes adsorption heat pumps, thermoelectric module applications, temperature control, heat flow measurement, heat transfer through insulation, heat transfer enhancement and green technology.



**Mike Tierney** is currently a Senior Lecturer in Process Systems at the University of Bristol, UK. He graduated from the University of Manchester, UK, in 1981 with a B.Sc. in Chemical Engineering and subsequently gained a Ph.D. from the University of Birmingham, UK. Until 1993, he was employed as a Senior Scientific Officer at Harwell Laboratory, researching heat and mass transfer in nuclear reactors and working with the CFX code. At Bristol, he first developed research interests in applied heat and mass transfer before proceeding to energy accountancy and adsorption heat pumps.



